Utah Department of Environmental Quality
Division of Drinking Water
Public Water System Inventory Report

PWS ID: UTAH29053   **Name:** GREEN HILLS COUNTRY ESTATES

Legal Contact GREEN HILLS CNTRY ESTATES WATER   **Rating:** Approved
TERRY A MURPHY   **Rating Date:** 04/13/1998
Address: PO BOX 453   **Activity Status:** Active
HUNTSVILLE, UT 84317
Phone Number: 801-564-9809
City Served (Area):
County: WEBER COUNTY

	Gal/Day	Gal/Min
System Type: Community **Last Inv Update:** 01/05/2011	**Avg Daily Prod:**	
Activity Status Cd: Active **Last Snty Srv Dt:** 06/25/2009	**Total Dsgn Cap:**	
Population: 205 **Surveyor:** LEE RICHARD PETERS	**Total Emerg Cap:**	
Oper Period: 1/1 to 12/31		

Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	MURPHY, TERRY A		801-745-2556	801-564-9809	murphy2556@msn.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	66
			66 **Total Svc Connections**

Storage

Total Storage: 220,000 GAL   **Number of Units:** 3   **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST003	STORAGE RESERVOIR #3	Ground	125,000	Concrete		A	
ST001	RESERVOIR #1	Ground	47,500 GAL	Concrete		A	
ST002	RESERVOIR #2	Ground	47,500 GAL	Concrete		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	BOOSTER STATION #2	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1 -1979	Active	WL	8	35 GPM	26 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL	8	80 GPM	100 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	GREEN HILLS SPRING	Inactive	SP				No	GW	Other		

Reports measured flow for wells, approved design capacity for all other sources.